

**Summary of Decisions of the Building Committee**  
**Building Committee II 22/2009 held on 30.6.2009**

(a) BCII 1 22/2009

Issue : Reduction in standard of natural ventilation for the proposed conversion from shop to office use.

Decision : Having noted the site constraint and the provision of central A/C, the committee had no objection to the granting of modification to permit a deficiency of 44.6% of openable window area.