

**Summary of Decisions of the Building Committee
Building Committee II 27/2009 held on 18.8.2009**

(a) BCII 1 27/2009

Issue : Proposed single storey industrial building to be served by an EVA of inadequate width.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement.

(b) BCII 2 27/2009

Issue : The major facades of a single family house with 3 domestic storeys over a basement carpark located at a distance of more than 10m from the EVA.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement.

(c) BCII 3 27/2009

Issue : Staircases on Upper G/F are not separated by integral protected lobby.

Decision : The committee, having considered the plans and the decision of Fire Safety Committee, did not accept non-provision of integral protected lobby.