

**Summary of Decisions of the Building Committee
Building Committee II 28/2009 held on 25.8.2009**

(a) BCII 1 28/2009

Issue : Non-provision of EVA to proposed 2-storey single-family houses.

Decision : The committee, having noted the site constraint and FSD's advice, accepted the non-provision of EVA.

(b) BCII 2 28/2009

Issue : Non-provision of EVA to a single storey transformer room.

Decision : The committee, having noted the site constraint and FSD's advice, accepted the non-provision of EVA.