

**Summary of Decisions of the Building Committee
Building Committee II 31/2009 held on 15.9.2009**

(a) BCII 1 31/2009

- Issue : (i) EVA for the proposed additional floor for a school building without turning space and inadequate loading capacity.
- (ii) Major façade of the proposed extension served by the EVA was less than 25% of the total length of all the perimeter walls of the building.
- Decision : (i) The committee, having considered the existing site constraint and FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures to FSD's satisfaction.
- (ii) The committee, having considered the existing site constraint and FSD's advice, accepted the EVA arrangement.

(b) BCII 2 31/2009

- Issue : Proposed EVA with width less than 13.5m and not in the form of two-way carriageway for a 4-storey extension and a shelter for the storage of containers.
- Decision : The committee, having noted the site constraint, accepted the deficiency of the EVA subject to acceptance of the same by FSD.