

**Summary of Decisions of the Building Committee
Building Committee II 36/2009 held on 20.10.2009**

(a) BCII 1 36/2009

Issue : Proposed self-closing hatch doors on the wall of RSMRR.

Decision : Having noted the concern on the operation and maintenance of the hatch doors. The committee asked for further information in ensuring the maintenance of the FRP of the wall

(b) BCII 2 36/2009

Issue : Major facades of proposed temporary building for exhibition located at a distance of more than 10m from the EVA of inadequate loading capacity.

Decision : The committee, having noted the site constraint and FSD's advice, accepted the proposed EVA arrangement.