

Summary of Decisions of the Building Committee
Building Committee II 42/2009 held on 1.12.2009

(a) BCII 1 42/2009

Issue : Non-provision of insulation in respect of FRP for lift landing doors of car lifts.

Decision : The committee, having studied the FRC Code, agreed that the proposed lift landing door was subject to the current practice, and the requirement of insulation was applicable to the lift landing doors as shown in the submitted plans.