

**Summary of Decisions of the Building Committee
Building Committee II 44/2009 held on 14.12.2009**

(a) BCII 1 44/2009

Issue : Proposed temporary bus depot to be served by an EVA of inadequate width.

Decision : The committee, having considered the site situation and FSD's verbal advice, accepted the proposed EVA arrangement subject to written confirmation of FSD on the acceptance of the proposed arrangement.

(b) BCII 2 44/2009

Issue : Proposed temporary bus depot to be served by an EVA of inadequate width.

Decision : The committee, having considered the site situation and FSD's verbal advice, accepted the proposed EVA arrangement subject to written confirmation of FSD on the acceptance of the proposed arrangement.

(c) BCII 3 44/2009

Issue : Portion of EVA without demarcation.

Decision : The committee, having noted the demarcation might cause confusion to the pilots, accepted portion of the EVA to be without demarcation subject to acceptance of the same by FSD.

(d) BCII 4 44/2009

Issue : (i) Proposed single-storey warehouse to be served by an EVA of inadequate width.

(ii) EVA is not provided to serve two opposite facades.

Decision : (i) & (ii) The committee, having noted the site constraint and FSD's advice, accepted the deficiency of the EVA.

(e) BCII 5 44/2009

Issue : Proposed multi-purpose hall used as PPE mixed with other uses for a residential housing block.

Decision : The committee noted that the multi-purpose hall was separated from the remaining part of the building and provided with independent MOE exits. The committee also noted that multi-purpose hall was a single storey structure without any other floor on top of it and the residential housing block was located away from the said hall. Having studied the design, the committee accepted the proposal.