

**Summary of Decisions of the Building Committee
Building Committee II 1/2010 held on 12.1.2010**

(a) BCII 1 1/2010

Issue : The major facades of an industrial building located at a distance of more than 10m from the EVA.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures to the satisfaction of DFS.

(b) BCII 2 1/2010

Issue : The distance from the fire service access point to the fireman's lift was more than 18m.

Decision : The committee, having considered the justification put forward by the AP, accepted the proposed arrangement subject to the acceptance of the same by FSD.