

**Summary of Decisions of the Building Committee
Building Committee II 4/2010 held on 2.2.2010**

(a) MAII 1 4/2010

Issue : Non-provision of insulation in respect of FRP for lift landing doors of car lifts.

Decision : The committee, having studied the FRC Code, agreed that the requirement of insulation was applicable to the lift landing doors as shown in the submitted plans.

(b) BCII 1 4/2010

Issue : Exemption from payment of fees for processing plans of A&A submission.

Decision : The committee noted that the proposal was wholly funded by government and was for the benefit of the general public. Having noted that there would not be loss of revenue to the Government, the committee agreed to the granting of exemption from payment of fees for processing plans.

(c) BCII 2 4/2010

Issue : Non-provision of emergency crash gate.

Decision : The committee, having considered the existing site situation and FSD's advice, accepted the replacement of emergency crash gate by folding gate subject to the condition imposed by FSD.

(d) BCII 3 4/2010

Issue : Exemption from payment of fees for processing plans of A&A submission.

Decision : Having considered the case, the committee could not identify valid justification for the granting of exemption from payment of fees for the processing plans submitted for approval under the B.O.