

**Summary of Decisions of the Building Committee**  
**Building Committee II 6/2010 held on 23.2.2010**

(a) BCII 1 6/2010

Issue : Non-provision of EVA for a proposed annex to the existing institutional building.

Decision : The committee, having noted the site constraint and FSD's advice, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures to the satisfaction of D of FS.