

Summary of Decisions of the Building Committee
Building Committee II 8/2010 held on 9.3.2010

(a) BCII 1 8/2010

Issue : Non-provision of insulation in respect of FRP for lift landing doors of car lifts.

Decision : The committee, having noted that a product meeting the insulation requirement was not available in the market, accepted the proposed arrangement subject to provision of enhanced fire safety measures and acceptance of the same by FSD.