

**Summary of Decisions of the Building Committee
Building Committee II 10/2010 held on 30.3.2010**

(a) MAII 1 10/2010

Issue : Proposed self-closing hatch doors on the wall of RSMRR.

Decision : The committee noted the advice of relevant outside departments and accepted that the proposal would be beneficial to the environment. Having studied the plans and considered the provision of enhanced safety measures, the committee agreed in-principle to the provision of self-closing hatch doors on the wall of RSMRR.

(b) BCII 1 10/2010

Issue : (i) Width of EVA less than 7.3m.

(ii) Non-provision of EVA for a building structure at play area.

Decision : (i) The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to written confirmation of FSD on the acceptance of the same arrangement.

(ii) The committee, having considered the site constraint and FSD's advice, accepted the non-provision of EVA.

(c) BCII 2 10/2010

Issue : Determination of the number and width of thoroughfare for place of public entertainment accommodating less than 500 persons.

Decision : The committee noted that the proposal was for existing historical buildings and the site constraints. Having noted the advice of FSD, the committee accepted the proposed thoroughfare arrangement.