

**Summary of Decisions of the Building Committee  
Building Committee II 13/2010 held on 20.4.2010**

(a) BCII 1 13/2010

Issue : Width of EVA less than 7.3m.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to written confirmation of FSD on the acceptance of the same arrangement.

(b) BCII 2 13/2010

Issue : Major façade of the proposed extension served by the EVA was less than 25% of the total length of the perimeter of the building.

Decision : The committee, having considered the existing site constraint and FSD's advice, accepted the EVA arrangement subject to the provision of enhanced fire safety measures and acceptance of the same by FSD.