

**Summary of Decisions of the Building Committee  
Building Committee II 16/2010 held on 11.5.2010**

(a) BCII 1 16/2010

Issue : Proposed composite development to be served by an existing EVA of inadequate turning radius.

Decision : The committee, having noted the existing site constraint and FSD's advice, accepted the non-provision of turning space for the EVA subject to the provision of enhanced fire safety measures.