

**Summary of Decisions of the Building Committee  
Building Committee II 18/2010 held on 25.5.2010**

(a) BCII 1 18/2010

Issue : Proposed refuge floor with one side open above safe parapet height on existing building.

Decision : The committee, having noted the site situation and FSD's advice, accepted the deficiency of the refuge floor subject to the provision of enhanced fire safety measures to the satisfaction of the D of FS.

(b) BCII 2 18/2010

Issue : Non-provision of EVA to a residential house.

Decision : The committee, having noted the site constraint and FSD's advice, accepted the non-provision of EVA.

(c) BCII 3 18/2010

Issue : Non-provision of EVA for an offshore site.

Decision : The committee, having noted the site constraint, accepted the non-provision of EVA.