Summary of Decisions of the Building Committee Building Committee II 22/2010 held on 6.7.2010

(a) <u>BCII 1 22/2010</u>

Issue : EVA to be steeper than 1 in 10.

Decision : The committee, having noted the site situation and FSD's advice,

accepted the deficiency of the EVA subject to the provision of

enhanced fire safety measures to the satisfaction of D of FS.