

**Summary of Decisions of the Building Committee
Building Committee II 25/2010 held on 27.7.2010**

(a) BCII 1 25/2010

- Issue : (i) Elements of construction of footbridge.
(ii) Perforated side enclosure of footbridge.
- Decision : (i) Having studied the case, the committee agreed that paragraph 6.1 of the FRC Code was applicable.
(ii) The committee agreed that the perforated side enclosure was not acceptable under B(C)R 90.