

**Summary of Decisions of the Building Committee
Building Committee II 28/2010 held on 17.8.2010**

(a) BCII 1 28/2010

Issue : Substandard EVA.

Decision : Having considered the existing site constraint and the advice of FSD, members advised and the Chairman **agreed** to the recommendation subject to the provision of enhanced fire safety measures to the satisfaction of the D of FS.

(b) BCII 2 28/2010

Issue : Non-provision of EVA

Decision : Having considered the existing site constraint and the advice of FSD, members advised and the Chairman **agreed** to the recommendation subject to the provision of enhanced fire safety measures to the satisfaction of the D of FS.

(c) BCII 3 28/2010

Issue : Discharge of surface water not to a public sewer within 30m of the building.

Decision : Having noted that there was no adverse comment from other departments, members advised and the Chairman **agreed** to the proposed arrangement for the discharge of surface water subject to the submission of design calculation for the petrol interceptor to demonstrate compliance with the requirements of EPD.