

**Summary of Decisions of the Building Committee  
Building Committee II 30/2010 held on 31.8.2010**

(a) BCII 1 30/2010

Issue : Non-provision of EVA for a residential house.

Decision : The committee, having noted the site constraint, accepted the non-provision of EVA subject to written acceptance of the same by FSD.

(b) BCII 2 30/2010

Issue : Proposed composite development to be served by an EVA of inadequate turning radius.

Decision : The committee, having considered the site situation and FSD's advice, accepted the deficiency of the EVA subject to the provision of enhanced fire safety measures.