

**Summary of Decisions of the Building Committee  
Building Committee II 32/2010 held on 14.9.2010**

(a) BCII 1 32/2010

Issue : Excessive distance to fireman's lift.

Decision : The committee, having considered the situation of the existing building, accepted the deficiency subject to acceptance of the same by FSD.

(b) BCII 2 32/2010

Issue : Non-provision of EVA for a residential development.

Decision : The committee, having noted the site constraint, accepted the non-provision of EVA subject to written acceptance of the same by FSD.

(c) BCII 3 32/2010

Issue : Proposed EVA of inadequate width.

Decision : The committee, having considered the existing site circumstances and FSD's advice, accepted the EVA arrangement.

(d) BCII 4 32/2010

Issue : EVA with inadequate width to serve facades having less than 25% of the total length of all the perimeter walls of the building.

Decision : The committee, having considered the site situation, accepted the deficiency of the EVA subject to the provision of enhanced fire safety measures and acceptance of the same by FSD in writing