

**Summary of Decisions of the Building Committee  
Building Committee II 36/2010 held on 12.10.2010**

(a) BCII 1 36/2010

Issue : Non-provision of turning space for an EVA with a dead end at TOP stage.

Decision : The committee, having noted the existing site constraint and FSD's advice, accepted the non-provision of turning space for the EVA subject to acceptance of the same by FSD in writing.

(b) BCII 2 36/2010

Issue : Non-provision of TBE room in a heritage hotel.

Decision : The committee, having studied the plans and considered the existing site circumstances, accepted the non-provision of TBE room subject to no objection from OFTA.