

**Summary of Decisions of the Building Committee
Building Committee II 45/2010 held on 14.12.2010**

(a) BCII 1 45/2010

Issue : Non-provision of EVA for a cemetery site.

Decision : The committee, having noted the site constraint, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures and acceptance of the same by FSD.

(b) BCII 2 45/2010

Issue : Non-provision of EVA to a building extension.

Decision : The committee, having noted the site constraint and the advice of FSD, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures to the satisfaction of FSD.