

**Summary of Decisions of the Building Committee
Building Committee II 46/2010 held on 21.12.2010**

(a) BCII 1 46/2010

Issue : Doorway giving direct access to the top of canopy.

Decision : Having considered the design, the committee did not accept the proposal under B(P)Reg 12.

(b) BCII 2 46/2010

Issue : Internal toilets with insufficient headroom.

Decision : Having considered the case, the committee did not accept internal toilets with insufficient headroom.