

**Summary of Decisions of the Building Committee
Building Committee II 22/2011 held on 31.5.2011**

(a) BCII 1 22/2011

Issue : Proof of ownership or realistic prospect of control of the land forming the site.

Decision : Noting from the LR record that the applicant was the registered owner of the lots, and the name of the owner tallied with that shown on Form BA 4, the committee accepted the proof of ownership of the site.

(b) BCII 2 22/2011

Issue : Mechanical ventilation with a lower air change rate to be provided for rooms with basins / sinks in a public hospital.

Decision : Having considered the case and the AP's justifications, the committee agreed in principle to the granting of modification under B(P)R 36.

(c) BCII 3 22/2011

Issue : Proof of ownership or realistic prospect of control of the land forming the site.

Decision : Noting from the LR record submitted by the AP that the applicant was the registered owner of the lot, and the name of the owner tallied with that shown on Form BA 4 and Form BA 5, the committee accepted the proof of ownership of the site.

(d) BCII 4 22/2011

Issue : Non-provision of EVA.

Decision : The committee, having noted the site circumstances and the advice of FSD, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures and acceptance of the same by FSD.