

**Summary of Decisions of the Building Committee
Building Committee II 44/2012 held on 13.11.2012**

(a) MAII 1 44/2012

Issue : Non-provision of turning spaces at deadend EVA and percentage of the total length of all the perimeter walls of the major façades of some buildings served by the EVA were less than 25%.

Decision : Having noted the site circumstances and the advice of FSD, the committee accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures as required by FSD.

(b) BCII 1 44/2012

Issue : Proof of ownership or realistic prospect of control of the land forming the site.

Decision : Having considered the documents submitted by the AP, the committee accepted the proof of realistic prospect of control of the land forming the site.