

**Summary of Decisions of the Building Committee
Building Committee II 7/2013 held on 19.2.2013**

(a) MAII 1 7/2013

Issue : Percentage of the total length of all the perimeter walls of the major façades of buildings served by the EVA was less than 25%.

Decision : Having regard to the site circumstances, the committee accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures and acceptance of the same by the D of FS.

(b) BCII 1 7/2013

Issue : Proof of ownership or realistic prospect of control of the land forming the site.

Decision : Noting from the LR record submitted by the AP that the applicant was the registered lot owner, and the owner's name tallied with that shown on the Form BA 4 and Form BA 5, the committee accepted the proof of ownership of the land forming the site.