Summary of Decisions of the Building Committee Building Committee II 9/2013 held on 5.3.2013

(a) MAII 1 9/2013

Issue : Discharge of required staircases into a public open space adjoining the

site.

Decision : Having studied the proposal, the committee had no in-principle

objection to the proposed MOE arrangement subject to confirmation of the concerned department that a permanent and unfettered right-ofway for MOE purpose would be provided and maintained within the

public open space during the lifetime of the proposed building.

(b) MAII 2 9/2013

Issue : Proof of ownership or realistic prospect of control of the land forming

the site.

Decision : Noting that the applicant had been authorized by the prospective

tenant to carry out the proposed works, the committee accepted the

proof of realistic prospect of control of the land forming the site.

(c) BCII 1 9/2013

Issue : Major facade of the building served by EVA was less than 25% of the

total length of all the perimeter walls of the building.

Decision : Having regard to the site circumstances, the committee accepted the

proposed EVA arrangement subject to the provision of enhanced fire

safety measures to the satisfaction of the D of FS.

(d) <u>BCII 2 9/2013</u>

Issue : EVA of inadequate width.

Decision : Having regard to the site circumstances, the committee accepted the

proposed EVA arrangement subject to the provision of enhanced fire

safety measures and acceptance of the same by the D of FS.

(e) <u>BCII 3 9/2013</u>

Issue : Major facade of the building served by EVA was less than 25% of the

total length of all the perimeter walls of the building.

Decision : Having regard to the site circumstances, the committee accepted the

proposed EVA arrangement subject to the provision of enhanced fire

safety measures to the satisfaction of the D of FS.

(f) BCII 4 9/2013

Issue : (i) Building provided with only one exit staircase.

- (ii) Footbridge connecting to an existing platform without approval record.
- (iii) Non-provision of EVA.

Decision : (i) Having studied the proposal, the committee did not accept the provision of only one exit staircase for the proposed building.

- (ii) Having regard to the site circumstances, the committee agreed that the construction and safety of the platform should be justified.
- (iii) Having regard to the site circumstances, the committee accepted the non-provision of EVA subject to the provision of enhanced fire safety measures and acceptance of the same by the D of FS

(g) <u>BCII 5 9/2013</u>

Issue : Proof of ownership or realistic prospect of control of the land forming

the site.

Decision : Noting from the document and LR record submitted by the AP that the

applicant was the registered owner of a portion of the lot and had been authorized by the remaining registered lot owners to represent them for building plan submission, the committee accepted the proof of

realistic prospect of control of the land forming the site.

(h) BCII 6 9/2013

Issue : Proof of ownership or realistic prospect of control of the land forming

the site.

Decision : Noting from the LR record submitted by the AP that the applicant was

the registered lot owner, and the owner's name tallied with that shown on the Form BA 4 and Form BA 5, the committee accepted the proof

of ownership of the land forming the site.