

**Summary of Decisions of the Building Committee
Building Committee II 14/2013 held on 9.4.2013**

(a) MAII 1 14/2013

Issue : Fire resistance rating of raised floors.

Decision : Having studied the design and noting FSI installed underneath the raised floor and D of FS's advice, the committee had no objection to the fire resistance rating of the proposed raised floors subject to the provision of enhanced fire safety measures and acceptance of the same by D of FS.

(b) BCII 1 14/2013

Issue : (i) Proof of ownership or realistic prospect of control of the land forming the site.

(ii) Non-provision of EVA.

Decision : (i) Noting from the document submitted by the AP that the applicant was the lot owner, and the owner's name tallied with that shown on the Form BA 4 and Form BA 5, the committee accepted the proof of ownership of the land forming the site.

(ii) Having regard to the site circumstances, the committee accepted the non-provision of EVA.