

**Summary of Decisions of the Building Committee  
Building Committee II 20/2016 held on 1.6.2016**

(a) BCII 1 20/2016

- Issues : (i) Lesser storage capacity for cesspool.
- (ii) Inadequate separation between cesspool and buildings in which people works.
- Decisions : (i) Having considered the proposal, the committee had no objection in principle to permit the cesspools with lesser storage capacity subject to further justifications.
- (ii) Having regard to the circumstances of the case, the committee had no objection in principle to allow the cesspools be located within 15m from buildings in which people works subject to further justifications.