

Summary of Decisions of the Building Committee
Building Committee II 23/2016 held on 3.8.2016

(a) BCII 1 23/2016

Issue : Mechanical ventilation at a rate of less than 10 air change per hour for rooms with waste fitments in a hospital.

Decision : Having considered the case and AP's justifications, the committee had no objection to the proposed rate of air change.