

Summary of Decisions of the Building Committee
Building Committee II 2/2017 held on 24.1.2017

(a) BCII 1 2/2017

Issue : Horizontal distance from fire service access point to the door of fireman's lift on ground floor greater than 18m.

Decision : Having regard to the site constraints and no adverse comment from the D of FS, the committee had no objection to the proposal.