

**Summary of Decisions of the Building Committee  
Building Committee II 4/2017 held on 14.2.2017**

(a) MAII 1 4/2017

Issue : Demountable protective barriers of inadequate height.

Decision : Having studied the proposal, the committee had no in-principle objection to accept the proposed protective barriers.

(b) BCII 1 4/2017

Issue : Exit routes discharging to covered area on G/F.

Decision : Having regard to the AP's justifications, the committee had no in-principle objection to the proposed MOE arrangement subject to further substantiations.

(c) BCII 2 4/2017

Issues : (i) Inadequate headroom of PPE premises.

(ii) PPE premises situated in a basement.

Decisions : (i) Having studied the proposal, the committee had no objection to the proposed headroom.

(ii) Having regard to the MOE arrangement and noting that the relevant requirements under FS Code Clause B27.3 were generally complied with, the committee had no objection to the proposal.