

**Summary of Decisions of the Building Committee
Building Committee II 5/2017 held on 11.4.2017**

(a) MAII 1 5/2017

- Issues : (i) Inadequate clear headroom of exit route in the existing building.
- (ii) Height of existing protective barriers in historic building not up to the current standard.
- Decisions : (i) The committee had no objection in principle to the deficiency in exit route headroom subject to the provision of compensatory and management measures.
- (ii) Having regard to the proposed compensatory measures, the committee had no objection to the existing protective barriers.