

**Summary of Decisions of the Building Committee
Building Committee II 7/2017 held on 2.5.2017**

(a) BCII 1 7/2017

Issue : PPE situated in a building which is used for purposes other than PPE.

Decision : Having regard to site circumstances and noting that the proposed PPE would comply with the criteria stipulated in Clause B19.2 of FS Code and had adequate fire separation from the remaining parts of the building, the committee agreed to grant a modification to permit the PPE use on the same floor with other non-domestic uses in the development.

(b) BCII 2 7/2017

Issue : Substandard connection of anti-syphonage pipe inside the sunken slab to the soil pipe.

Decision : Having regard to the site circumstance and AP's proposed remedial measure, the committee accepted in-principle the drainage connection subject to AP's further remedial works.