

**Summary of Decisions of the Building Committee
Building Committee II 10/2017 held on 20.6.2017**

(a) BCII 1 10/2017

Issue : Existing combustible timber roof of a historic building.

Decision : The committee noted that the proposed compensatory measures were in line with the Practice Guidebook for Adaptive Re-use of and Alteration and Addition Works to Heritage Buildings. Having considered the circumstances and noting the conservation needs as well as the support of the relevant department, the committee had no objection to the proposal.

(b) BCII 2 10/2017

Issue : Existing combustible timber roof of a historic building.

Decision : The committee noted that the proposed compensatory measures were in line with the Practice Guidebook for Adaptive Re-use of and Alteration and Addition Works to Heritage Buildings. Having considered the circumstances and noting the conservation needs as well as the support of the relevant department, the committee had no objection to the proposal.

(c) BCII 3 10/2017

Issue : Non-provision of fireman's lift.

Decision : Having regard to the circumstances of the site, the committee did not accept the non-provision of fireman's lift in the school building.