Summary of Decisions of the Building Committee Building Committee II 15/2017 held on 5.9.2017

(a) <u>BCII 1 15/2017</u>

Issues : Passage from the fire services access point to the fireman's lift not

separated from the remainder of ground storey by FRR walls.

Decision : Having considered the site circumstances, the compensative measures

proposed by the AP and noting that there would be no change in use to the existing building, the committee had no objection to the proposed

means of access for firefighting and rescue.