

**Summary of Decisions of the Building Committee
Building Committee II 16/2017 held on 13.9.2017**

(a) BCII 1 16/2017

Issue : Soil fitments of the development will not be/are not provided with a supply of water from the waterworks or from a well.

Decision : Having regard to the circumstances of the case, the committee had no objection to accept the proposal of using stream water as flushing water supply for all the 3 Phases of the development subject to the submission of undertaking letter to engage a water supplier for emergency and contingency purposes.

(b) BCII 2 16/2017

Issue : The proposed steel structure with staircase supporting the HRSG and associated exhaust duct do not comply with the requirements for Fire Resisting Construction (FRC) and Means of Escape (MOE) under FS Code 2011.

Decision : Having regard to the circumstances of the case, the committee had no objection to waive the requirements for FRC and MOE under FS Code 2011.