

**Summary of Decisions of the Building Committee
Building Committee II 17/2017 held on 3.10.2017**

(a) BCII 1 17/2017

Issue : The proposed steel structure with staircase and platform supporting the HRSG and associated exhaust stack did not comply with the requirements for Fire Resisting Construction (FRC) and Means of Escape (MOE) under FS Code 2011.

Decision : Having regard to the circumstances of the case, the committee had no objection to waive the requirements for FRC and MOE under FS Code 2011.