

**Summary of Decisions of the Building Committee  
Building Committee II 24/2017 held on 19.12.2017**

(a) BCII 1 24/2017

Issue : Non-provision of fire barriers for a building within 900mm from the common boundary abutting on a landscape area.

Decision : Having studied the case and noting the relevant statutory controls and the comments of relevant departments, the committee had no objection to the proposed arrangements for fire separation.

(b) BCII 2 24/2017

Issue : PPE situated in a building which is used for purposes other than PPE.

Decision : Having regard to site circumstances and noting that the proposed PPE would comply with the requirements stipulated in the FS Code and had adequate fire separation from the remaining parts of the building, the committee agreed to grant a modification to permit the PPE use on the same floor with other non-domestic uses in the development.