

**Summary of Decisions of the Building Committee  
Building Committee II 6/2018 held on 3.4.2018**

(a) BCII 1 6/2018

- Issues : (i) Assessment of occupant capacity based on actual counting for the calculation of MOE provisions.
- (ii) Assessment of occupant capacity based on actual counting for the calculation of sanitary fitment provisions.

Decisions : The committee, having considered the AP's justifications, the design, nature, use and management of the development and no objection from other departments, accepted the occupant capacity based on actual counting for the purpose of MOE and sanitary fitment calculations.