

**Summary of Decisions of the Building Committee
Building Committee II 7/2018 held on 25.4.2018**

(a) BCII 1 7/2018

Issue : Fire service access point (FSAP) not provided in the perimeter of the building.

Decision : The committee had no objection to the proposed FSAP arrangement having regard to the AP's justifications and noting no adverse comments from the D of FS.

(b) BCII 2 7/2018

Issue : Proof of realistic prospect of control of the land forming the site.

Decision : Noting the applicant was holding a significant percentage of the units/land forming the site and had indicated steps to acquire the outstanding ownership, the committee accepted in principle the proof.