

Summary of Decisions of the Building Committee
Building Committee II 15/2018 held on 28.8.2018

(a) BCII 1 15/2018

Issue : Discharge of required staircases into a public open space adjoining the site.

Decision : Having studied the proposal, the committee had no in-principle objection to the proposed MOE arrangement subject to confirmation of the concerned department that a permanent and unfettered right-of-way for MOE purpose would be provided and maintained within the public open space during the lifetime of the proposed building.