

Summary of Decisions of the Building Committee
Building Committee II 13/2019 held on 30.7.2019

(a) BCII 1 13/2019

Issue : Drains and sewers under buildings.

Decision : Having regard to the circumstances of the case, the committee had no objection to the use of the ductile iron pipes under buildings.