

**Summary of Decisions of the Building Committee**  
**Building Committee II 7/2021 held on 29.6.2021**

(a) BCII 1 7/2021

- |           |   |       |   |
|-----------|---|-------|---|
| Issues    | : | (i)   | Inadequate headroom of PPE premises.  |
|           |   | (ii)  | Protective barriers of inadequate height.   |
|           |   | (iii) | Non-provision of handgrip in intersecting gangways of PPE premises.   |
|           |   | (iv)  | Inadequate width of gangway of PPE premises.  |
|           |   | (v)   | Inadequate number, size and fall of drain.  |
| Decisions | : | (i)   | Having studied the proposal, the committee had no objection to the proposed headroom.   |
|           |   | (ii)  | Having studied the proposal, the committee had no in-principle objection to accept the proposed protective barriers subject to enhanced design. |
|           |   | (iii) | Having studied the proposal, the committee had no objection to the proposed central continuous handrail, other than the provision of handgrip.  |
|           |   | (iv)  | Having studied the proposal, the committee had no objection to the proposed width of gangway.   |
|           |   | (v)   | Having studied the proposal, the committee had no objection to the proposed siphonic drainage system.   |