

**Summary of Decisions of the Building Committee**  
**Building Committee II 1/2022 held on 8.2.2022**

(a) BCII 1 1/2022

- Issues : (i) Number and width of exit doors and exit routes for storey having an occupant capacity of more than 3,000 persons.
- (ii) Fire service access points not on the ground storey.
- Decisions : (i) Having considered the circumstances of the case, the committee had no objection to the proposed assessment of the required number and width of exit doors and exit routes.
- (ii) Having regard to the site circumstances and no adverse comment from relevant department, the committee had no objection to the proposal.