

Summary of Decision of the Building Committee
Building Committee II 10/2022 held on 5.10.2022

(a) BCII 1 10/2022

- Issues : (i) Arrangement of the fire service access points.
- (ii) Passage from the fire services access point to the fireman's lift not separated from the remainder of building by FRR walls.
- Decisions : (i) Having regard to circumstances of the case, the committee had no objection to the proposed arrangement.
- (ii) Having studied the proposal, the committee agreed to defer the decision pending for further justifications to be provided for consideration.

(b) BCII 2 10/2022

- Issue : Locking device of exit doors.
- Decision : Having regard to special circumstances of the case, the committee had no objection to proposed door locking device.