

**Summary of Decision of the Building Committee**  
**Building Committee II 1/2024 held on 27.2.2024**

(a) BCII 1 1/2024

- Issues : (i) Existing stairs with substandard risers for place of public entertainment at a historic building.
- (ii) Non-provision of central handrail to existing stairs at a historic building.
- (iii) Existing substandard protective barriers in a historic building.
- Decisions : (i)&(ii) Having considered the circumstances of the case and the proposed compensatory and management measures, the committee had no objection to the deficiencies of existing stairs.
- (iii) Having considered the circumstances of the case and the proposed compensatory and management measures, the committee had no in-principle objection to the deficiencies of existing protective barriers.