

Summary of Decisions of the Structural Engineering Committee
SEC Meeting 02/2026 held on 24.2.2026

Case 02/2026

Issue: Use of Galvanized Steel Mesh and Fire-retardant Fine Mesh Safety Vertical Net for the Bamboo Catchfan and Screen Cover for Demolition Works

Recommendation: To accept the following:

1. Fire-retardant fine mesh safety vertical net in lieu of the heavy-duty Polyethylene net specified in Table 3.3 (Minimum Specification for Polyethylene Net) of the Code of Practice for Demolition of Buildings 2004 (Code); and
2. Galvanized Steel Mesh in lieu of the additional heavy-duty nylon net as mentioned in Clause 3.3.2 (C) (1) – Amendment 2016 to the Code.

Decision: Having noted the background information, members had no objection to endorsing the paper on a case-by-case basis.