

Summary of Decisions of the Structural Engineering Committee  
SEC HD-01/2011 held on 20.01.2011

(a) Case HD-01/2011

- Issue: Use of a method for remote measurement of the final set and temporary compression of driven H-piles
- Recommendation: To accept the use of a method for remote measurement of the final set and temporary compression ( $C_p + C_q$ ) of drive H-piles by Piles Driving Monitor (PDM); and hence the use of the PDM final set graph in the submission of Form BA 14 for certification of completion of pile works.
- Decision: Members endorsed the recommendation on the condition that all the quality control and supervision measures adopted before shall be strictly adhered to.