

Summary of Decisions of the Structural Engineering Committee
SEC 11/2011 held on 23.09.2011

(a) Case 11/2011

- Issue: Use of 63.5 mm diameter high strength DBS BAREX (grade 555/700) hot rolled thread bars in Mini-piles socketted into Rock
- Recommendation: The use of 63.5 mm diameter high strength DBS BAREX (grade 555/700 i.e. $f_y = 520\text{MPa}$) hot rolled thread bars as steel bars without bends in the mini-piles socketted into rock at this site be accepted.
- Decision: Finding RSE's justification insufficient, members did not endorse the recommendation.